

Weatherproof Telephone Sounder and Lighting

Model: D13-LP



Analogue telephone line

Heavy duty telephone



Housing	industrial standard coated steel body
Colour	Red box + blue beacon
Protection degree	IP 66 (IEC 529)
Operating position	Wall or ceiling mounting
Temperature range	Operation-20 to +70°C Storage-40 to +85°C
Weight	0.5 kg
Signalling device	The signalling device is telephone line is powered by electricity.
Telephone line and Volume	Telephone line powered Approx. 90 dB(A) at 1m distance
Beacon	Beacon flashing when telephone ringing
Call voltage	24 VAC to 75 VAC
exchange voltage	24 VDC to 63 VDC
Mounting:	Wall mounting





HONGKONG KOON TECHNOLOGY LIMITED

268#, Nangchang industrial park, Gushu, Baoan district, Shenzhen, China




Tel: 0086755 29116322 ext 8005 Fax: 0086755 29790278

Email: jenny@koontech.com

www.koontech.com





Test report EN 60529:2001 IDT Degrees of protection provided by enclosures (IP Code)	
Report	---
Report reference No.	TH16DR-176S
Tested by (+signature)	Robert 
Reviewed by (+signature)	Prince 
Date of issue	Apr 10, 2016
	
Testing laboratory	---
Name	Shenzhen Tian Hai Test Technology Co.,Ltd.
Address	FL.1, No.2 BLDG,Yalian Industrial Zone, Wuhe Road, Bantian street, Longgang District, Shenzhen, China
Test location	Same as above
Client Name	Hongkong Koon Technology Limited
Address	6th/F, 268# building, Nanchang industrial park, Gushu, Baoan Shenzhen, China
Model no.	D1,D2,D3,D4,D5,D6,D7,D8,D9,D10,D11,12,D13,D14,D15,D16,D17 D18
Description	Koophone Alarm Sundermtech Weatherproof Tele
Rating(s)	AC110-240 powered or DC 12V 24 VDC to 63 VDC
Manufacturer	Hongkong Koon Technology Limited
Address	6th/F, 268# building, Nanchang industrial park, Gushu, Baoan Shenzhen, China
Test specification	
Standard	EN 60529:2001 IDT
Operating conditions	continuous operation
Level of protection	IP65
Equipment rating	---
Trade mark	GELID Solutions
Note	N/A
Test case verdicts	
Test case does not apply to the test object	N (Not apply)
Test item does meet the requirement	P(Pass)
Test item does not meet the requirement	F(Fail)
Report Number: TH16DR-176S	Page 1 of 6
No.2 BLDG,Yalian Highstar Industrial Zone,Wuhe Road No.5022,Bantian street,Longgang District,Shenzhen Tel:+86-755-86615100 Fax:+86-755-86615105 http://www.tianhaitest.com	